



*Neuadd y Sir / County Hall, Llandrindod, Powys, LD1 5LG*

## **QUESTIONS AT ANY TIME TO CABINET PORTFOLIO HOLDERS**

Response by the Portfolio Holder:

The electricity supply to the council's street lighting is only sufficient to power the relatively low powered lanterns on the lighting columns which have a maximum loading of 2kw. To allow for EV chargers which require 7 - 22kw for relatively a low powered charger would require an upgrade to the supply and this is not feasible at this time. In London they will have greater access to a much better network to allow connections which can meet the needs of the column mounted EV chargers.